

BRE Global Limited

Bucknalls Lane, Garston, Watford, Hertfordshire, United Kingdom WD25 9XX
Telephone: +44(0)1923 664100 Fax: +44(0)1923 664603 E-mail: enquiries@breglobal.co.uk Web: www.breglobal.co.uk

EC-CERTIFICATE OF CONFORMITY

0832 - CPD - 0142

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Symphoni High Output SYHO/C Conventional Type A fire alarm wall sounder for use in fire detection and alarm systems

(For conditions of use for the product see the attached appendix)

placed on the market by

Cooper Fulleon Limited
Llantarnam Park, Cwmbran, South Wales, NP44 3AW

and produced in the factory

Cooper Fulleon Limited
Llantarnam Park, Cwmbran, South Wales, NP44 3AW

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan. The initial type-testing for the relevant characteristics of the product, the initial inspection and continuous surveillance of the factory and factory production control has been performed under the control of the approved body BRE Global Limited.

This certificate attests that all provisions concerning the attestation of conformity (Level 1) and the performances described in Annex ZA of the standard(s)

EN 54 - 3: 2001 + A1: 2002 + A2: 2006 - Sounders

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 7/10/2005 and remains valid as long as the product continues to be manufactured and the conditions laid down in the harmonised technical specification referenced or the manufacturing conditions in the factory or the FPC itself are not modified significantly and the required annual FPC assessments are maintained.



Eman Mattie-Suleiman
Certification Manager
For and on behalf of BRE Global Limited

Date of Issue: 30/8/2011
Issue Number: 3
Page: 1 of 2

This certificate remains the property of BRE Global Limited and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.

To check the authenticity of this certificate, please visit our website or contact us.

BRE Global Limited

Bucknalls Lane, Garston, Watford, Hertfordshire, United Kingdom WD25 9XX

Telephone: +44(0)1923 664100 Fax: +44(0)1923 664603 E-mail: enquiries@breglobal.co.uk Web: www.breglobal.co.uk

Appendix to EC Certificate of conformity 0832 - CPD - 0142

The details and conditions of use for the Symphoni High Output SYHO/C Conventional Type A fire alarm wall sounder, placed on the market by Cooper Fulleon Limited Llantarnam Park, Cwmbran, South Wales, NP44 3AW are:

To be used in accordance with the suppliers installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Bases:

Standard mounting back box

Sounder Tones:

3 - Sweep 800Hz - 970Hz in 1s

7 - Slow whoop 500Hz - 1200Hz in 3.5s - 0.5s silence

8 - Sweep 1200Hz - 500Hz in 1s

14 - Continuous 970Hz steady

29 - Alternating 990Hz 250ms / 650Hz 250ms

30 - Alternating 510Hz 250ms / 610Hz 250ms

Variants:

/C - All colours variants

/WP - Weatherproof version (Type B)



Eman Mattie-Suleiman
Certification Manager
For and on behalf of BRE Global Limited

Date of Issue: 30/8/2011

Issue Number: 3

Page: 2 of 2

This certificate remains the property of BRE Global Limited and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.

To check the authenticity of this certificate, please visit our website or contact us.